

WideArea[™] Eye/Face Washes

G1727 WideArea™ Eye/Face Wash, Recess Deck Mounted, Push-Down Valve □ G1730 WideArea™ Eye/Face Wash, Recess Deck Mounted, Ball Valve with Flag Handle



Application: WideArea[™] eye/face wash for recessed mounting in countertop. Four GS-Plus[™] spray-type outlet heads deliver a flood of water over a wide area of coverage for complete rinsing of eyes and face.

Spray Head Assembly: Four GS-Plus[™] spray heads. Each head has a "flip top" dust cover, internal flow control and filter to remove impurities from the water flow.

Valve: 1/2" IPS brass stay-open ball valve. G1727 has valve mounted below counter and activated by push-down knob. G1730 has valve mounted above counter and activated by flag handle.

Bowl: 13" diameter flanged stainless steel bowl for recessed mounting in countertop. Furnished with all hardware necessary for installation in counter.

Valve Supply: 1/2" NPT male inlet.

Waste: 1-1/4" NPT female outlet.

Sign: ANSI-compliant identification sign.

Quality Assurance: Unit is completely assembled and water tested prior to shipment.

Available Options

- **T** Chrome plated brass tailpiece and trap with 1-1/2" IPS waste connection.
- **TP** 1-1/2" OD chrome plated brass tailpiece.
- **G3600LF** Thermostatic mixing valve precisely blends hot and cold water to deliver warm (tepid) water as required by ANSI Z358.1-2014. Refer to "Tempering Valves" section for complete technical and product selection information.


312 447 8100 TELEPHONE







G1727 WideArea™ Eye/Face Wash, Recess Deck Mounted, Push-Down Valve □ G1730 WideArea[™] Eye/Face Wash, Recess Deck Mounted, Ball Valve with Flag Handle



Sign Included



Due to continuing product improvement, the information contained in this document is subject to change without notice. All dimensions are \pm 1/4" (6mm). rev. 081018

Guardian Equipment 1140 N North Branch St Chicago, IL 60642

THIS SPACE FOR ARCHITECT/ENGINEER APPROVAL

312 447 8100 TELEPHONE 312 447 8101 FACSIMILE gesafety.com

Listed 8116. Units have been tested to and comply with ANSI Z358.1-2014 and the Uniform Plumbing Code.

