


G1692 VERTICALLY MOUNTED CORROSION-RESISTANT EMERGENCY SHOWER WITH ALL-STAINLESS STEEL CONSTRUCTION



UNITS (EXCEPT THOSE WITH SELF-CLOSING VALVES) COMPLY WITH THE REQUIREMENTS OF ANSI Z358.1.

TEST ALL EMERGENCY EQUIPMENT AT LEAST WEEKLY.

Approved:

Revision Number: 061704-TPS