

PROCENTEC



ProfiHub A5

User Manual

User Manual ProfiHub A5



- 5 Isolated Channels
- Transparent for all PROFIBUS DP protocols
- RS 485 specifications for each channel
- Max. 12 Mbps
- Max. 31 devices per channel
- Max. 1200 m spur line length
- No limit in serial placement
- No address required
- Integrated termination facilities
- Configurable grounding system
- IP 65 classification

“5 channel DP spur and
repeater component”

Safety Guidelines

This manual contains notices which you should observe to ensure your own personal safety, as well as to protect the product and connected equipment. These notices are highlighted in the manual by a warning sign and are marked as followed according to the level of danger:



Draws your attention to important information on handling the product, a particular part of the documentation or the correct functioning of the product.

Warning

This device and its components may only be used for the applications described in this manual and only in connection with devices or components that comply with PROFIBUS and an RS 485 interface.

This product can only function correctly and safely if it is transported, stored, set up, installed, operated and maintained as recommended.

Qualified Technicians

Only qualified technicians should be allowed to install and work with this equipment. Qualified technicians are defined as persons who are authorized to commission, to ground, to tag circuits and systems in accordance with established safety practices and standards. It is recommended that the technicians carry a Certified PROFIBUS Installer or Certified PROFIBUS Engineer certificate.

Disclaimer of Liability

We have checked the contents of this manual as much as possible. Since deviations cannot be precluded entirely, we cannot guarantee full agreement. However, the content in this manual is reviewed regularly and any necessary corrections included in subsequent editions. Suggestions for improvement are welcomed.

Copyright © 2011-2016 PROCENTEC

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted, in any form or by any means, electronic, mechanical, photocopying, recording or otherwise, without the prior written permission of the publisher.

Important information

Purpose of the Manual

This manual explains how to put the ProfiHub A5 into operation.

Recycling and Disposal

The parts of the ProfiHub can be recycled. For further information about environment-friendly recycling and the procedure for disposing of your old equipment, please contact:

PROCENTEC
Klopperman 16
2292 JD WATERINGEN
The Netherlands

T: +31-(0)174-671800

F: +31-(0)174-671801

E: info@procentec.com

W: www.procentec.com

Document Updates

You can obtain constantly updated information on PROCENTEC products on the internet at www.procentec.com

You can also contact PROCENTEC Customer Support:

- by phone at +31-(0)174-671800
- by fax at +31-(0)174-671801
- by email at support@procentec.com

Content

- User Manual ProfiHub A5 2
- Important information 4
- 1. The Product 6
 - 1.1 Product Features7
 - 1.2 Application areas7
 - 1.3 Additional Benefits8
 - 1.4 Channel Structure8
 - 1.5 Grounding System9
 - 1.6 Cable lengths for PROFIBUS DP9
 - 1.7 Cable types for PROFIBUS DP10
 - 1.8 Status Display11
 - 1.9 Comparison Table12
- 2. Installation Instructions ProfiHub A5..... 13
 - 2.1 Location13
 - 2.2 Position13
 - 2.3 Mounting13
 - 2.4 Power Supply13
 - 2.5 Backbone14
 - 2.6 Spur Segments15
 - 2.7 Termination16
 - 2.8 Baudrate switch16
- 3. Technical Data ProfiHub A5 18
- 4. Sales offices and Distributors 20
- 5. Order Codes 25
- 6. Glossary 26
- 7. Certificates 29
- 8. Revision History 32
- 9. Other PROCENTEC products 33
- 10. About PROCENTEC 35
- 11. Notes 36

1. The Product

The ProfiHub A5 is an advanced, flexible and robust network component for PROFIBUS DP installations, to implement long multi-device spur lines and backbone structures with star/tree segments.

PROFIBUS DP is a high speed communication bus that has to comply with strict rules concerning spur lines, because of possible reflections that could lead to communication disturbances. If spur lines or star segments are required, costly investments in repeaters have to be done.

An innovative component for such applications is the ProfiHub A5. This is a perfect economic solution to implement reliable spur lines in high speed DP networks. It has the functionality of 5 galvanic isolated transparent repeaters. This allows network structures with extended spur lines that individually can handle a maximum of 31 devices and a length equal to the main bus. The ProfiHub A5 refreshes a received message on one Channel and transfers it to all the other Channels (chicken foot topology).

Because the ProfiHub A5 creates isolated segments, the devices can now be removed and added during operation. Also electrical bus problems and EMC disturbances in a spur do not spread to the other segments. The intelligent logic and isolation circuits of the ProfiHub does not change the bit width. This means the ProfiHub does not have limitations in serial placement. The logic also detects the transmission speed automatically.

To assist the installation work, termination is integrated and can be switched on/off. The grounding concept is also selectable: direct or capacitive grounding. The ProfiHub A5 is powered by a 10 to 32 DC Voltage (110/230V AC versions are also available). For troubleshooting, maintenance and commissioning the ProfiHub A5 is equipped with a LED display on the outside, which indicates the status of each Channel (Data and Error).



1.1 Product Features

- 5 Galvanic isolated channels (repeater segments)
- Transparent for all PROFIBUS DP protocols
- DP - RS 485 specifications for each channel
- 9,6 Kbps to 12 Mbps
- 31 devices per channel
- 1200 m spur line length (depends on transmission speed)
- No limit in serial placement or cascading of ProfiHubs
- No address required
- Integrated termination facilities (switches)
- Configurable grounding system (direct or capacitive)
- IP 65 classification




Fig. 1- Long spur lines to instruments and the possibility to remove/insert them during operation. Short circuit protection on each spur line is automatically provided.

1.2 Application areas

- Dynamic spur lines to actuators, flow meters and pH analysers
- Removable drives and motors
- Pull/plug motor control centres (drawers)
- Roof mounted devices in tank farms
- Dirty and humid environments
- Barrier for non-galvanic isolated equipment
- Large star/tree structured networks
- Outdoor applications with device and cable stress

1.3 Additional Benefits

- Hot slave insertion and removal during operation
- Short circuit protection on each channel
- Compact and robust construction
- Status and error display (per channel)
- Suitable for all DP cables
- Conveniently arranged networks
- Easy extendable installations
- Standard glands can be replaced with M12
- On-board DB9 female connector for maintenance activities
- Cost savings




Fig. 2- Because of the isolation and intelligence the ProfiHub provides, it can be used as a barrier for electrically sensitive segments. This keeps the backbone and other Channels clean.

1.4 Channel Structure

Every Channel is electrically isolated and internally connected to the transparent intelligent backbone. The termination is switchable and powered by the ProfiHub. The shielding of the PROFIBUS cable can be directly grounded or indirectly grounded (see the next paragraph).




Fig. 3- Channel structure

1.5 Grounding System

The ProfiHub A5 can be grounded by 3 methods:

- 1 Direct grounding
- 2 Indirect grounding (through a capacitor)
- 3 Combination of direct and indirect

The power supply must be grounded directly on the power connector. The shielding of the PROFIBUS cables can be directly or indirectly grounded. If you do not want to ground all or some cables to the common ground, i.e. compensating current, the cable shielding must be connected to pin 'I' which stands for Indirect grounding. A capacitor with a parallel high value resistor will separate the 2 potentials (Fig. 3), ensuring protection of the signal against non-DC disturbances.

If by accident on 1 channel the Direct Grounding is connected with the Indirect Grounding, the connection to the Direct Grounding bypasses the capacitor in the Indirect Ground connection. The current on the shield will flow to Direct Ground.

1.6 Cable lengths for PROFIBUS DP

The cables on the Channels and the Main-Channel should comply with the PROFIBUS DP cable specifications for RS 485 (Fig. 4).

| | | | | | | | | | | |
|------------------------------|------------|-------------|--------------|--------------|--------------|------------|-------------|-------------|-------------|--------------|
| Baudrate (kbit/s) | 9.6 | 19.2 | 45.45 | 93.75 | 187.5 | 500 | 1500 | 3000 | 6000 | 12000 |
| Segment length (m) | 1200 | 1200 | 1200 | 1200 | 1000 | 400 | 200 | 100 | 100 | 100 |
| Segment length (feet) | 3940 | 3940 | 3940 | 3940 | 3280 | 1310 | 656 | 328 | 328 | 328 |




Fig. 4- Cable lengths for PROFIBUS DP

1.7 Cable types for PROFIBUS DP

The cable type should comply with the PROFIBUS DP cable specifications for RS 485 (Fig. 5).

| Parameter | Value |
|------------------------|-------------------------------|
| Wires | 2 (twisted) |
| Impedance | 135 .. 165 Ohm at 3 to 20 MHz |
| Capacity | < 30 pF/m |
| Loop resistance | < 110 Ohm/km |
| Wire diameter | > 0.64 mm |
| Wire area | > 0.32 mm ² |

Fig. 5- PROFIBUS DP cable specifications

The ProfiHub A5 can handle cables based on multiple protection sheaths with a diameter between 6 to 12 mm (Fig. 6).




Fig. 6- Cables with different protection sheaths

1.8 Status Display

The Status Display on the ProfiHubs is very useful for diagnostics.

| | OFF | Blinking | ON |
|----------------------|--|--|--|
| POWER | ☹️ Power is not switched on or an internal failure. | ☹️ Power supply not stable or an internal failure. | 😊 Power supply OK. |
| Main READY | ☹️ Power is not switched on or an internal failure. | ☹️ Trying to detect the transmission speed, but has not locked it yet. | 😊 The transmission speed has been detected. |
| Main RX-OK | ☹️ No communication detected on the Main-Channel. | 😊 1 or more devices communicating on the Main-Channel. | 😊 1 or more devices communicating on the Main-Channel. |
| Main ERROR | 😊 No problem has been detected. | ☹️ Problem in the cabling has been detected (Main Channel). | ☹️ Problem in the cabling has been detected (Main Channel). |
| Channel RX-OK | ☹️ There is no communication detected (on this Channel). | 😊 1 or more devices communicating (on this Channel). | 😊 1 or more devices communicating (on this Channel). |
| Channel ERROR | 😊 No problem has been detected. | ☹️ Problem in the cabling has been detected (on this Channel). | ☹️ Problem in the cabling has been detected (on this Channel). |

1.9 Comparison Table

| | ProfiHub A5 | ProfiHub B5+R |
|---------------------|--|------------------------------------|
| Area | IP 65 | IP 20 |
| Housing | Plastic | Metal |
| Mounting | Corner screws | DIN-rail |
| Weight | 800 g | 650 g |
| Dimensions | 213 x 210 x 95 mm | 167 x 111 x 32 mm |
| PROFIBUS connectors | Screw terminals (inside) Glands (outside) | Screw terminals and DB9 connectors |
| Redundant channels | No | Yes |
| Diagnostics slave | No | Optional (B5+RD) |

2. Installation Instructions ProfiHub A5

2.1 Location

The ProfiHub A5 can be installed everywhere in a non-hazardous area that complies with IP 65 (DIN 40 050) and the specified temperature range of -40 to +75° Celsius.

2.2 Position

The ProfiHub A5 can be installed in every position, but it is recommended to install it with the cable glands pointing down to create a more reliable protection against moist and dust (water compartment and glands). In this position it is also easier to read the status display.

2.3 Mounting

The ProfiHub A5 has 4 mounting holes for 4..5 mm screws (Fig. 7). To reach the holes on position 1 and 2, the top lid has to be removed.




Fig. 7- Positions of the mounting holes.



It is recommended to mount the ProfiHub A5 with at least 4 suitable screws/bolts in position 1, 2, 3 and 4.

Be careful with the flat cable that connects the lid with the PCB.

2.4 Power Supply

The 4-pin screw type power connector is located on the bottom left of the PCB (Fig. 8).




Fig. 8- Power connector and LEDs

The power supply has to comply with the following specifications:

- Voltage: 10 to 32 Vdc
- Current: Min. 130 mA
- Wire diameter: < 2,5 mm²
- Cable thickness: 5 to 10 mm

Procedure

To connect the 24V supply to the 4-pin screw-type terminal, proceed as follows:

- Strip the insulation from the cable or the conductors for the 24V power supply
- Secure the conductors in the screw-type terminal

Note: There is a grounding point that can be used.

To connect the power supply, you need a 3 mm screwdriver.

Testing

If the power is switched on it can be diagnosed by the following indicators on the PCB:

- All the LEDs should be shortly blinking
- The READY LED is ON or Blinking
- The voltage LEDs are ON (5V, 3V3 and 1V8)



It is recommended to use a power supply with a ground lead (3-wire).

2.5 Backbone

Connect the DP backbone cable to the bottom connector of the Main-Channel (Fig. 9). If the ProfiHub is not the last device on the bus segment, connect the Bus-Out cable to the top connector of the Main-Channel (Fig. 9).




Fig. 9- PROFIBUS DP backbone connection

Pin Layout of the screw terminals

Pin "A": Green wire

Pin "B": Red wire

Pin "I": Cable shielding *OR*

Pin "⌚": Cable shielding

Testing

If the Main-Channel recognizes valid PROFIBUS messages from 1 or more connected devices, the RX-OK LED of this Channel should be blinking.

2.6 Spur Segments

Connect the spur segments to the connectors of Channel 1 to 5 (Fig. 10).




Fig. 10- PROFIBUS DP spur connectors

Pin Layout of the screw terminals

Pin "A": Green wire

Pin "B": Red wire

Pin "I": Cable shielding *OR*

Pin "⌚": Cable shielding

Testing

If a Channel recognizes valid PROFIBUS messages from 1 or more connected devices, the RX-OK LED of the specific Channel should be blinking.

2.7 Termination

The termination of the Main-Channel has been set to OFF by default. If the ProfiHub is the last/first device on the segment, the termination should be set to ON (Fig. 11).

The termination of the Channels have been set to ON by default. Because it is assumed that the new segment is started at the ProfiHub (Fig. 11).




Fig. 11- Termination Switches



Don't forget to switch the termination ON at the other end of the segment and make sure it is powered continuously.

2.8 Baudrate switch

The ProfiHub recognizes the transmission speed by default. If it is required that the ProfiHub is locked to a certain transmission speed, switch S100 should be set to the required value (Fig. 12). The switch can be reached by removing the top lid.




Fig. 12– Baudrate speed switch

To set the transmission speed, you need a 3 mm screwdriver.

Switch values:

- 0 = Auto detect (default)
- 1 = 9,6 kbps
- 2 = 19,2 kbps
- 3 = 45,45 kbps
- 4 = 93,75 kbps
- 5 = 187,5 kbps
- 6 = 500 kbps
- 7 = 1500 kbps
- 8 = 3000 kbps
- 9 = 6000 kbps
- A = 12000 kbps
- B .. F = Auto detect

3. Technical Data ProfiHub A5

| Technical data ProfiHub A5 | |
|---------------------------------------|---|
| Dimensions and weight | |
| Dimensions L x W x H (mm) with glands | 213 x 210 x 95 mm |
| Weight | Approximately 800 g |
| Mounting screws | 4 to 5 mm |
| Ambient conditions | |
| Operating temperature | -40 to +75° Celsius |
| Isolation class | IP 65 (DIN 40 050) |
| Protocol specifications | |
| Supported Protocols | DP-V0, DP- V1, DP-V2, FDL, MPI, FMS, PROFIsafe, PROFIdrive and any other FDL based protocol. |
| Transmission speed | 9,6 kbps to 12 Mbps (including 45,45 kbps) |
| Transmission speed detection | Auto detect (default) or settable with a rotary switch |
| Transmission speed switch | 0 = Auto detect (default) 1 = 9,6 kbps 2 = 19,2 kbps 3 = 45,45 kbps 4 = 93,75 kbps 5 = 187,5 kbps 6 = 500 kbps 7 = 1500 kbps 8 = 3000 kbps 9 = 6000 kbps A = 12000 kbps B .. F = Auto detect |
| Transmission speed detection time | < 10 s (if it is set to auto detect) |
| Data delay time | 1,25 TBit at 9,6 kbps to 93,75 kbps 1,3 TBit at 187,5 kbps to 500 kbps 1,4 TBit at 1,5 Mbps 1,6 TBit at 3 Mbps 2,0 TBit at 6 Mbps 3,0 TBit at 12 Mbps |
| Delay time jitter | Max. ¼ bit time |

Technical data ProfiHub A5

PROFIBUS cable specifications

| | |
|------------------------------------|--|
| Cable lengths | 1200 m at 9,6 kbps to 93,75 kbps 1000 m at 187,5 kbps 400 m at 500 kbps 200 m at 1,5 Mbps 100 m at 3 Mbps to 12 Mbps |
| Cable thickness | 6 to 12 mm |
| Wire diameter | < 2,5 mm ² |
| Wire type | Stranded or Solid core |
| Number of devices | Maximum 31 per Channel (including ProfiHubs, OLMs, Laptops/PCs, etc) |
| Termination | Integrated and switchable. Powered according to IEC 61158 (390/220/390 Ohms) - All channels (default on) - Main-channel (default off) |
| Cascading depth | No limits |
| Redundancy | No |
| Power supply specifications | |
| Nominal supply voltage | 10 to 32 Vdc |
| Current consumption | 130 mA at 24 V power supply (all channels fully loaded) |
| Power dissipation | Max. 4,1 W |
| Reverse polarity protection | Yes |
| Cable thickness | 5 to 10 mm |
| Wire diameter | < 2,5 mm ² |
| Others | |
| MTBF | Not available |

4. Sales offices and Distributors

HEADQUARTERS

PROCENTEC
Klopperman 16
2292 JD WATERINGEN
Netherlands

T: +31-(0)174-671800
F: +31-(0)174-671801
E: info@procentec.com
I: www.procentec.com

ARGENTINA

eFALCOM
Alcorta 2411
B1744 - Moreno
Buenos Aires
Argentina

T: +54 237 46 31 151
F: +54 237 46 31 150
E: santiago.falcomer@efalcom.com
I: www.efalcom.com.ar

AUSTRALIA

IS Systems Pty Limited
14 Laverick Ave.,
Tomago
NSW, Australia, 2322

T: +61 2 4964 8548
F: +61 2 4964 8877
E: fritz.woller@issystems.com.au
I: www.issystems.com.au

Pentair Flow Control Pacific
1 Percival Road
Smithfield
NSW, Australia, 2164

T: +61 2 4448 0466
F: +61 2 4423 3232
E: sharee.hazell@pentair.com.au
I: www.profibuscentre.com.au

BELGIUM and LUXEMBOURG

Bintz Technics N.V.
Brixtonlaan 23
B-1930 Zaventem
Belgium

T: +32 2 720 49 16
F: +32 2 720 37 50
E: bloemen@bintz.be
I: www.bintz.be

BRAZIL

Westcon Instrument. Indl Ltda
Rual Alvaro Rodrigues, 257
São Paulo – SP
Brazil - CEP 04582-000

T: +55 11 5561-7488
F: +55 11 5093-2592
E: paolo@wii.com.br
I: www.wii.com.br

CANADA

Streamline Process Management Inc.
#3, 4351 – 104 Ave SE
Calgary, Alberta T2C 5C6
Canada

T: +1 403 225 1986
F: +1 587 585 2828
E: admin@streamlinepm.com
I: www.streamlinepm.com

CHILE

RP Ingenieria Limitada
Tucapel 92 oficina 52
Concepción
Chile

T: +56-(0)41-2469350
F: +56-(0)41-2522592
E: rodrigopinto@rpingeneria.cl
I: www.rpingeneria.cl

CHINA

PROCENTEC Beijing
Room E-1115 WangJingYuan YouLeHui
ChaoYang
Beijing
China

T: +86(10)84766911 or 84787311
F: +86(10)84766722
E: info@procentec.net
I: www.procentec.net

CZECH REPUBLIC

FOXON s.r.o.
Polní 367
460 01 Liberec 12
Czech Republic

T: +420 484 845 555
F: +420 484 845 556
E: foxon@foxon.cz
I: www.foxon.cz

DENMARK

ProSaiCon
Jernbanegade 23B
DK 4000 Roskilde
Denmark

T: +45 70 20 52 01
F: +45 70 20 52 02
E: hfj@prosaicon.dk
I: www.prosaicon.dk

EGYPT

Mas Trading
37, 105 Street
Al-Etihad Square
Egypt

T: +2 02 2524 2842
F: +2 02 2524 2843
E: aya.elshafei@masautomation.com
I: www.masautomation.com

ESTONIA

Saksa Automaatika OU
Peterburi Tee 49
Tallinn
EE-11415 Estonia

T: +372 605 2526
F: +372 605 2524
E: info@saksa-automaatika.ee
I: www.saksa-automaatika.ee

FINLAND

Hantekno Oy
Kalliotie 2
04360 Tuusula
Finland

T: +358 40 8222 014
E: info@hantekno.com
I: www.hantekno.fi

FRANCE

AGILiCOM
Bâtiment B
1, rue de la Briaudière
Z.A. La Châtaigneraie
37510 BALLAN-MIRE
France

T: +33 247 76 10 20
F: +33 247 37 95 54
E: jy.bois@agilicom.fr
I: www.agilicom.fr

GERMANY

PROCENTEC GmbH
Benzstrasse 15
D-76185 Karlsruhe
Germany

T: +49-(0)721 831 663-0
F: +49-(0)721 831 663-29
E: info@procentec.de
I: www.procentec.de

INDIA

UL Engineering Services & Software Pvt Ltd
Nirman Classic,
Katraj-Kondhwa Road,
Katraj, Pune-411046
India

T: +91-202 696 0050
F: +91-202 696 2079
E: dileep.miskin@ulepl.com
I: www.ulepl.com

IRELAND

PROFIBUS Ireland
Automation Research Centre
University of Limerick
National Technology Park, Plassey
Limerick
Ireland

T: +353-61-202107 or +35361240240
F: +353-61-202582
E: info@profibus.ie
I: www.profibus.ie

ISRAEL

Instrumentics Industrial Control
8 Hamlacha St.
New Industrial Zone
Netanya, 42170
Israel

T: +972-9-8357090
F: +972-9-8350619
E: info@instrumentics-ic.co.il
I: www.inst-ic.co.il

ITALY

PROCENTEC Italy
Via Branze n. 43/45
25123 Brescia
Italy

T: +39 030 200 8610
F: +39 030 238 0059
E: www.procentec.it
W: www.procentec.it

JAPAN

TJ Group
C/O Japanese PROFIBUS Organisation
West World Building 4F
3-1-6 Higashi-Gotanda,
Shinagawa-ku,
Tokyo, 141-0022
Japan

T: +81-3-6450-3739
F: +81-3-6450-3739
E: info@profibus.jp

KOREA

Hi-PRO Tech. Co., Ltd.
#2802, U-Tower, 1029
Youngduk-dong, Giheung-gu
Yongin-Si, Kyunggi-do,
446-908 Korea

T: +82 82-31-216-2640
F: +82 82-31-216-2644
E: chays@hiprotech.co.kr
I: www.profibus.co.kr

LEBANON

Industrial Technologies S.A.L. (ITEC)
Point Center, Boulevard Fouad Chehab
Sin El Fil
Beirut
Lebanon

T: +961 1 491161
F: +961 1 491162
E: sales@iteclb.com
I: www.iteclb.com

MEXICO

Grid Connect Inc.

T: +1 530-219-2565 (Spanish)
E: tomf@gridconnect.com
I: www.gridconnect.com

NETHERLANDS

PROCENTEC B.V.
Klopperman 16
2292 JD Wateringen
Netherlands

T: +31 (0)174 671800
F: +31 (0)174 671 801
E: info@procentec.com
I: www.procentec.com

NORWAY

Nortelco Automation AS
Johan Scharffenbergs vei 25
N-0694 Oslo
Norway

T: +47 22 57 61 00
E: post@nortelcoautomation.no
I: www.nortelcoautomation.no

PERU

ControlWare
Jr. Los Silicios 5409
Los Olivos - L39
Peru

T: +51 1637 3735
F: +51 1528 0454
E: info@controlware.com.pe
I: www.controlware.com.pe

POLAND

INTEX Sp. z o.o.
ul. Portowa 4
44-102 Gliwice
Poland

T: +48 32 230 75 16
F: +48 32 230 75 17
E: intex@intex.com.pl
I: www.intex.com.pl

ROMANIA

S.C. SVT Electronics S.R.L.
Brăila 7
540331 Tg-Mure
Romania

T: +40 365 809 305
F: +40 365 809 305
E: sajgo.tibor@svt.ro
I: www.svt.ro

SAUDI ARABIA

ASM Process Automation
Al-Zahra Dist. – Attas st.
cross section with helmy Kutby St.
Villa no.25
Jeddah-21553
Saudi Arabia

T: +966 2 691 2741
F: +966 2 682 8943
E: info@asmestablishment.com
I: www.asmeestablishment.com

SINGAPORE / SOUTH EAST ASIA

Allegro Electronics
236 Serangoon Avenue 3 07-98
Singapore 550236

T: +65 62878063
E: sales@allegro.com.sg
I: www.allegro.com.sg

Gissmatic Automatisierung Pte Ltd
318 Tanglin Road 01-34
Singapore 247979

T: +65 900 912 76
E: sales@gissmatic.com
I: www.gissmatic.com

SLOVAKIA

ControlSystem s.r.o.
Stúrova 4
977 01 BREZNO
Slovakia

T: +421 486115900
F: +421 486111891
E: jan.snopko@controlsystem.sk
E: jan.snopko@controlsystem.sk

SOUTH AFRICA

IDX ONLINE CC
1 Weaver Street
Fourways
Johannesburg
South Africa - 2191

T: +27(11) 548 9960
F: +27(11) 465-8890
E: sales@idxonline.com
I: www.idxonline.com

SPAIN

LOGITEK, S.A
Ctra. de Sant Cugat, 63 Esc. B Planta 1ª
Rubí (BARCELONA), 08191
Spain

T: +34 93 588 6767
E: xavier.cardena@logitek.es
I: www.logitek.es

SWEDEN

P&L Nordic AB
Box 252
S-281 23 Hässleholm
Sweden

T: +46 451 74 44 00
F: +46 451 89 833
E: hans.maunsbach@pol.se
I: www.pol.se/profibus

SWITZERLAND

Berner Fachhochschule
PROFIBUS Kompetenzzentrum
Jlcoweg 1
CH-3400 Burgdorf
Switzerland

T: +41 (0) 34 426 68 32
F: +41 (0) 34 426 68 13
E: max.felser@bfh.ch
I: www.profitrace.ch

TAIWAN

Full Data Technology
6F., No.200, Gangqian Rd.
Neihu District, Taipei City
114, Taiwan

T: +886-2-87519941/9097
F: +886-2-87519533
E: sales@fulldata.com.tw
I: www.fulldata.com.tw

TURKEY

Emikon Otomasyon
DES Sanayi sitesi 103 sokak
B-7 blok No:16 Yukari Dudullu / Umraniye
Istanbul 34776
Turkey

T: +90 216 420 8347
F: +90 216 420 8348
E: tolgaturunz@emikonotomasyon.com
I: www.emikonotomasyon.com

UNITED ARAB EMIRATES

Synergy Controls
907, IT Plaza Silicon Oasis :
Dubail
United Arab Emirates

T: +971 4 3262692
F: +971 4 3262693
E: sales@synergycontrols.ae

UNITED KINGDOM and N. Ireland

Verwer Training & Consultancy
5 Barclay Road
Poynton, Stockport
Cheshire SK12 1YY
United Kingdom

T: +44 (0)1625 871199
E: andy@verwertraining.com
I: www.verwertraining.com

Hi-Port Software
The Hub 2 Martin Close
Lee-on-Solent
Hampshire PO13 8LG
United Kingdom

T: +44 (0)8452 90 20 30
F: +44 (0)2392 552880
E: sales@hiport.co.uk
I: www.hiport.co.uk

iTech
Unit 1
Dukes Road
Troon
Ayrshire KA10 6QR
United Kingdom

T: +44 (0)1292 311 613
F: +44 (0)1292 311 578
E: sales@itech-troon.co.uk
I: www.itech-troon.co.uk

Parkelect Ltd.
84 Dargan Road
Belfast
BT3 9JU
N. Ireland

T: +44 2890 777743
F: +44 2890 777794
E: jgillan@parkelect.co.uk
I: www.parkelect.co.uk

UNITED STATES

Grid Connect Inc.
1630 W. Diehl Road
Naperville, Illinois 60563
USA

T: +1 630 245-1445
F: +1 630 245-1717
E: sales@gridconnect.com
I: www.gridconnect.com/procentec.html





VIETNAM

Bavitech Corporation
42 Truong Son Street
Ward 2, Tan Binh District
Ho Chi Minh City
Vietnam

T: +84-8-3547 0976
F: +84-8-3547 0977
E: hai.hoang@bavitech.com
I: www.bavitech.com

For the up to date list of the Sales Offices and Distributors see www.procentec.com/company/distributors/. If your country or region is not listed, please contact us. We are still searching for distributors who can cover complete areas or countries.

5. Order Codes

| Component | Order code | Remarks |
|--|------------|--|
|  <p>ProfiHub A5</p> | 16010 | Includes mounting set |
|  <p>ProfiHub A5 with 110V / 230VAC to 24VDC transformer</p> | 16013 | Includes mounting set Includes power transformer in lid Input power: 110 to 230 VAC instead of 24 VDC |
|  <p>Ground rail</p> | 16011 | The ground rail has to be mounted inside the casing to supply a common grounding area for all cable shielding. It improves the EMC behaviour and it supplies a good construction for vibrations. Not useable for capacitive grounding! |
|  <p>M12 female flange set</p> | 16012 | Set of 5 pieces (female) |

6. Glossary

| | |
|-----------------|--|
| Address | Unique number of a device connected to the network. With PROFIBUS this can be 0 to 126. 127 is a broadcast address |
| Analyzer | Software tool to observe the protocol traffic. Combi-analyzers can also inspect the signal quality Other term: Bus Monitor Example: ProfiTrace |
| Backbone | The primary bus cable. Most of the time only the control systems, ProfiHubs and fiber optic couplers are connected to this cable. The field devices are connected behind the ProfiHubs and fiber optic couplers. |
| Bit Time (TBit) | The bit time TBit is the time, which elapses during the transmission of one bit. It depends on the baudrate and is calculated as follows $TBit = 1 \text{ (bit)} / \text{baudrate (bps)}$. Examples: 12 Mbps --> TBit = 83 ns 1,5 Mbps --> TBit = 667 ns |
| Busparameters | Settings that define the timing behavior on the bus. They are defined in the master. Examples: Tslot, MaxTSDR. |
| C | Capacitance |
| DGND | Digital ground |
| DIN | German Institute for Standardization (www.din.de) |
| DP-V0 | DP-V0 is the basic stage of the PROFIBUS DP communication protocol. DP-V0 devices (master and slaves) perform the following basic functionalities: <ul style="list-style-type: none"> • Cyclic exchange of I/O data between controlling and slave devices • Device, identifier (module) and channel related diagnosis • Parameterization of DP-slaves • Configuration of DP-slaves |
| DP-V1 | DP-V1 is the first stage of extension of PROFIBUS DP after DP-V0. DP-V1 devices shall comply with the following features: <ul style="list-style-type: none"> • Device related diagnosis is replaced by status and alarms. • The first three octets of the user parameterization data are now standardized • Optionally these devices may support: <ul style="list-style-type: none"> • Acyclic communication (MS1, MS2) • If alarms are used, MS1 shall be supported |

| | |
|-------------------------------|--|
| DP-V2 | <p>DP-V2 is the second stage of extension of PROFIBUS DP after DP-V1. DP-V2 devices shall comply with the following features:</p> <ul style="list-style-type: none"> • Data Exchange Broadcast (DxB) for slave to slave communication (publisher/subscriber principle) • Isochronous Mode (time tick synchronized operating slaves, e.g. drives) • Up- and/or download of Load Region Data (domains) • Clock Control (synchronization within slaves) and Time Stamping • Redundancy |
| Electromagnetic Compatibility | See <i>EMC</i> |
| EMC | The extent to which an electric or electronic device will tolerate electrical interference from other equipment (immunity), and will interfere with other equipment. Within the European Community as well as in other countries it is regulated by law that electric and electronic components and equipment comply with basic standards such as IEC 61000-6-2 or IEC 61326 or corresponding individual product standards. |
| Hub | A Hub refreshes a signal and passes the information on to all nodes which are connected to the Hub. Data frames which were received on one port are transferred to all the other ports (chicken foot topology). |
| MPI | Multiple Protocol Interface. Protocol defined by Siemens which uses the layer 1 and 2 of PROFIBUS (FDL). |
| PCB | Printed Circuit Board |
| PROFIBUS DP | <p>Acronym for "PROFIBUS for Decentralized Peripherals". Specification of an open fieldbus system with the following characteristics:</p> <ul style="list-style-type: none"> • Polling master-slave-system (cyclic communications, MS0) • Flying masters with robin round token passing coordination (MM) • Connection based (MS1) and connectionless (MS2, MS3) acyclic communication between masters and slaves <p>Options (e.g.):</p> <ul style="list-style-type: none"> • Data exchange broadcast (DXB), i.e. slave to slaves communication • Isochronous mode of slaves • Clock synchronization • Redundancy <p>PROFIBUS DP is standardized within IEC 61158 and IEC 61784, communication profile families 3/1 and 3/2.</p> <p>The term "PROFIBUS DP" also is a synonym for the RS485 based deployments within factory automation.</p> |

| | |
|-------------|--|
| Repeater | Active physical layer device that receives and retransmits all signals over a different port to increase the distance and number of devices for which signals can be correctly transferred for a given medium. |
| Spur line | A cable attached to a bus segment with a T-connection . Spurs are not recommended with PROFIBUS DP. They are prohibited with 12 Mbps and PROFIsafe operations. German term is "Stichleitung". |
| Stub line | See <i>Spur line</i> |
| TBit | See <i>Bit Time</i> |
| Termination | A (powered) resistor network at both ends of a segment to prevent reflections (with PROFIBUS DP the termination has to be powered). |
| Topology | In a communications network, the pattern of interconnection between network nodes; e.g. bus, ring, star configuration. |
| PI | PROFIBUS International, the International PROFIBUS Organization based in Karlsruhe. |
| PNO | PROFIBUS Nutzer Organization, tThe German PROFIBUS Organization based in Karlsruhe. |
| Drop cable | See <i>Spur line</i> |
| Reflection | Part of the original signal that is transmitted back along the cable. It corrupts the original signal. |

7. Certificates



certificatie

QualityMasters hereby declares that

Procentec B.V.
Wateringen

has a management system that meets the requirements of the standard
NEN-EN-ISO 9001:2008

for the scope

Providing training courses, technical support, product development and the exploitation of the test laboratory.

| | |
|---------------------------|------------|
| Date of original approval | 10-02-2003 |
| Date of issue | 25-01-2016 |
| Valid until | 10-02-2019 |
| Certificate number | NL 6594-uk |

On behalf of Stichting QualityMasters,



N.B. The failure to meet the conditions as set forth in the certification agreement, or non-compliance with the given standard and/or guidelines, may lead to the suspension or cancellation of the certificate. This certificate remains the property of Stichting QualityMasters, Nieuwland Parc 157, 3351 LJ Papendrecht.



**Certificate
for a PI Competence Center**

PI confirms that

**PROCENTEC
Elmer Vis
Klopperman 16
2292 JD WATERINGEN
NETHERLANDS**

is a fully accredited PI Competence Center for
PROFIBUS basic
PROFIBUS Process Automation
PROFIsafe.

This certificate is granted according to the Quality of Services Agreement for
PI Competence Centers and is valid until December 31, 2017.



(Official in Charge)

Chairmen of PI



(Karsten Schneider, Chairman)



(Michael J. Bryant, Deputy Chairman)



PROFI®
BUS

Certificate

Authorization as PI Test Laboratory for PROFIBUS

PROFIBUS Nutzerorganisation e.V. accepts
PROCENTEC
Klopperman 16
2292 JD Wateringen
The Netherlands

as authorized PI Test Laboratory for:

PROFIBUS Slave Devices
PA Profile Devices

The authorization is based on the assessment dated February 19, 2015, and the related assessment report.


The execution of the tests aimed in the PROFIBUS certification shall be conform to the PROFIBUS Standard and the valid guidelines.

This authorization is valid until December 31, 2016.




(Official in Charge)

Board of PROFIBUS Nutzerorganisation e. V.



(K. Schneider)



(K.-P. Lindner)



PROFI
BUS

8. Revision History

V 3.0.0

- Completely changed to new Corporate Identity
- Removed all ProfiHub B5 information
- Updated certificates
- Updated paragraph 1.5

9. Other PROCENTEC products

PROFINET Cable Tester

- Suitable for 4- and 8-wire PROFINET and regular Ethernet cables
- Suitable for straight and 90°, metal or plastic PROFINET plugs
- Tests cable shielding
- Detects short circuits, wire breaks, swaps, miswiring and split pairs
- Large LCD clearly indicates the test results
- 150 hours on one 9 V battery
- Operating temperature: 0 to 50 °C
- Just 1-key-press to start continuous testing
- It can also test telephone and coax cable



www.procentec.com/products/profinet-products

Compact PROFIBUS Repeater

- Single channel PROFIBUS repeater
- Transparent
- Increased signal strength
- 12 Mbps
- Auto baudrate detection
- Redundant power supply
- Digital glitch filtering
- No limit in cascading
- Integrated switchable termination
- Diagnostic LEDs
- DB9 connector for measurements
- IP 20 with DIN-rail mounting



www.procentec.com/products/profihub

ProfiHub B5+R

- 6 galvanically isolated channels
- Configurable grounding system
- Redundant power supply
- Bus redundancy option
- Star, tree and bus structured networks
- Alarm contact
- Monitoring port per channel
- IP20
- Certifications: UL Listed, DNV, FCC, CE

www.procentec.com/products/profihub



ProfiTrace

- Busmonitor for DP and PA with powerful statistics
- Oscilloscope - ScopeWare
- Bar graph
- Topology scan
- Reporting
- 3-Color network condition indicator
- DP master - ProfiCaptain
- ProfiCore Ultra USB interface
- OPC server and CommDTM
- Windows XP, Vista, 7 and 8 platforms
- Multi language user interface

www.procentec.com/products/profitrace





10. About PROCENTEC

PROCENTEC is a specialist in PROFIBUS and PROFINET technology and develops products to optimize the production processes of end users. Our innovative solutions ensure that our customers successfully operate in the world of industrial automation and enjoy maximum results from their process.

PROCENTEC globally supplies all the components required to install a measurable and steerable network. We develop and produce all products in the Netherlands and they are exported through our worldwide distribution network. At PROCENTEC, we have a professional team of qualified support engineers who provide technical support on-site and online. Our professionals have more than 20 years of experience with PROFIBUS and PROFINET technology. They provide the necessary support to end users during implementation procedures, certification processes, audits and malfunctions. PROCENTEC also is an international accredited Competence and Training centre for PROFIBUS and PROFINET. We provide training courses that help employees using those techniques optimally for their business objectives

Products

- ProfiTrace
- ComBricks
- ProfiHub
- PROFINET tools
- Cables & Connectors

Services

- On-site & Online Support
- Network Audit
- Network Certification
- Consultancy
- Testlab & Democenter
- Competence Center

Training

- PROFIBUS training courses
- PROFINET training courses
- Product training courses



PROCENTEC BV
Klopperman 16
2292 JD Wateringen
The Netherlands

T: +31 (0)174 671 800

F: +31 (0)174 671 801

E: support@procentec.com

W: www.procentec.com

